



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received

Code

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY - ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title IMC		Edition 2006
Section number and title 502.8.3 Indoor dispensing and use		Page 36
Proponent Michael J. Koppes	Title Fire Protection Engineer	
Address 401 South Grant Street, West lafayette, IN 47907-2024		Phone 765-494-1427
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>502.8.3 Indoor dispensing and use. Indoor dispensing and use areas for hazardous materials in amounts exceeding the maximum allowable quantity per control area shall be provided with exhaust ventilation in accordance with Section 502.7.1 <u>502.8.1.1</u>.</p>		
REASON		
Code references the wrong section.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		